

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

PAUL AND FRANCES MIZE	)	
	)	
COMPLAINANTS	)	
	)	
vs.	)	CASE NO. 95-471
	)	
BARNESBURG WATER ASSOCIATION,	)	
INC.	)	
	)	
DEFENDANT	)	

O R D E R

On May 5, 1997, the Complainants in this proceeding notified the Commission by letter that their complaint had been satisfied. A copy of this letter is attached. On May 9, 1997, South Eastern Water Association, Inc. ("South Eastern"), as the successor of Barnesburg Water Association, Inc., filed with the Commission a statement as well as pressure recording charts which indicated that the Complainants' pressure problems had indeed been addressed. As South Eastern has satisfied the Complainants, their complaint should be dismissed.


IT IS THEREFORE ORDERED that this case be dismissed and removed from the Commission's docket.

Done at Frankfort, Kentucky, this 6th day of June, 1997.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director

Steffen

RECEIVED

MAY 05 1997

PUBLIC SERVICE  
COMMISSION

4/29/97

Public Service Commission  
730 Schenkel Lane  
Post Office Box 615  
Frankfort, Ky. 40602

RECEIVED  
MAY 08 1997  
GENERAL COUNSEL

RE: Case No. 95-468  
Barnesburg Water Association, Inc.

This letter is to inform you that the Barnesburg Water Service has installed a pump and a tank on our water line at the corner of Rainey Road and Miller/Mize Lane. This system has made a real difference in our service. The pressure is constant and there have been no outages since completion of this system. We understand that the intent of the Barnesburg Water Service is to build a bigger line in the very near future that will improve our service so that the pump and tank will no longer be needed. As it stands now, we are satisfied with the service we have, with the knowledge that it may even be better with the completion of that larger line.

We appreciate all the work the Public Service Commission has done to see that our service has been improved.

We are also thankful that the new personnel at Barnesburg Water Service seem not only concerned with our problems, but do try to solve them as well.

Sincerely,

*James H. Mize Jr. & Juanda*  
Mr. & Mrs. James H. Mize, Jr.

*Paul & Frances Mize*  
Mr. & Mrs. Paul Mize

*Juanita Mize*  
Juanita Mize

128 Miller Mize Lane  
Somerset, Ky 40503